

WARNING

**Hot Work In Progress
Watch For Fire!**

**In Case of Emergency
Call 911**

Location of Nearest :

Telephone _____

Pull Station _____

HOT WORK CHECKLIST

Date _____ W.O. # _____
Time Started _____ Time Finished _____
Building _____
Room # _____ Floor _____
Location on Floor _____
Nature of Job _____

____ Welding ____ Brazing ____ Soldering ____ Heating ____ Grinding ____ Cutting ____ Jet Torch ____ Other

TYPE OF EQUIPMENT TO BE USED:

____ Electrical Arc
____ Grinding
____ Hot Iron
____ Open Flame Torch
____ Cutting
____ Other _____

REQUIRED PRECAUTIONS CHECKLIST

- | | |
|---|--|
| ____ Sprinklers, fire hose, extinguishers are in service and are operational. | ____ Remove combustibile material where possible. Otherwise protect with fire resistive tarpaulins or metal shields. |
| ____ Hot work equipment is in good condition. | ____ All floor and wall openings covered. |
| ____ Appropriate PPE is worn. | ____ Construction is non-combustible and without combustibile covering or insulation. |
| ____ Appropriate area shielding equipment is used. | ____ Combustibles on the other side of the walls moved away. |
| ____ DPS notified of work conducted 5pm-7am, weekdays and holidays. | ____ Enclosed equipment cleaned of all combustibles. |
| ____ Adequate ventilation available or provided. | ____ Containers purged of flammable liquids and vapors. |
| ____ Piping valved/blanked off. | ____ Fire Watch if necessary (name): |
| ____ Other precautions taken: _____ | _____ |
| _____ | _____ |
| _____ | _____ |

FIRE SAFETY PRECAUTIONS

- | | |
|---|--|
| ____ Flammable liquids, dust, lint, oil, deposits removed. | ____ Fire Watch will be provided during and after work for 30 minutes, including coffee or lunch breaks. |
| ____ Explosive atmosphere in area eliminated. | ____ Fire Watch supplied and trained in the use of extinguishers, hose, alarms, phone emergency numbers. |
| ____ Floors clean/clear of combustibles. | ____ Fire Watch may be required for adjoining areas, above and below floors or obstructions. |
| ____ Combustible floors wet down, covered with fire-resistant material. | |

I verify the above location has been examined. The precautions checked on the Required Precautions Checklist have been taken to prevent fire and permission is authorized for this work.

1. Checklist will be retained by worker(s) during job.
2. When job is completed, checklist will be returned to Worker's Foreman or DPS.
3. Checklist is good for one shift only.

Signed _____
employee

Completed Checklist Shall be Posted Outside Immediate Area