

APPENDIX K
Rubber Insulating Equipment Test Intervals

TABLE E RUBBER INSULATING EQUIPMENT TEST INTERVALS	
TYPE OF EQUIPMENT	WHEN TO TEST
Rubber insulating line hose	Upon indication that insulating value is suspect and after repair.
Rubber insulating covers	Upon indication that insulating value is suspect and after repair.
Rubber insulating blankets	Before first issue and every 12 months thereafter; ¹ upon indication that insulating value is suspect; and after repair.
Rubber insulating gloves	Before first issue and every 6 months thereafter; ¹ upon indication that insulating value is suspect; after repair; and after use without protectors.
Rubber insulating sleeves	Before first issue and every 12 months thereafter; ¹ upon indication that insulating value is suspect; and after repair.

¹ If the insulating equipment has been electrically tested but not issued for service, the insulating equipment shall not be placed into service unless it has been electrically tested within the previous 12 months.

APPENDIX L
American Society of Testing Materials Standards

TABLE 3 AMERICAN SOCIETY OF TESTING MATERIALS STANDARDS			
STANDARD TITLE	ASTM NUMBER	EDITION	SUPPLEMENT
Standard Specification for Rubber Insulating Gloves	D-120	2009	-
Standard Specification for Rubber Insulating Matting	D-178	2001	2010
Standard Specification for Rubber Insulating Blankets	D-1048	2012	-
Standard Specification for Rubber Insulating Covers	D-1049	1998	2010
Standard Specification for Rubber Insulating Line Hose	D-1050	2005	2011
Standard Specification for Rubber Insulating Sleeves	D-1051	2008	-
Standard Specification for In-Service Care of Insulating Line Hose and Covers	F-478	2009	-
Standard Specification for In-Service Care of Insulating Blankets	F-479	2006	2011
Standard Specification for In-Service Care of Insulating Gloves And Sleeves	F-496	2008	-